

GOVERNMENT OF TELANGANA
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT

From:
District Fire Officer
Medak at Patancheru

To: ✓
The Principal,
St.Mary's D.Ed College,
Lingareddy Pally, Siddipet, Medak District.

Rc.No.254/A1/2014, Dated: 30-01-2015.

Sir,

Sub:- **Telangana State Disaster Response & Fire Services Department - Central Region - Medak District-** Issuance of No Objection Certificate for Occupancy to the Existing Educational Building of St.Mary's D.Ed College, Sy.No.381,382, Lingareddy Pally, Siddipet, Medak District- Reg.

- Ref:** - 1. Section 13 (2) of A.P. Fire Services Act, 1999 and Rule 15(2) of A.P. Fire and Emergency Operations and Levy of Fee Rules, 2006.
2. Chief Office instructions Memo.Rc.No.2305/B2/2007, dt.28-02-2007 and 12-09-2008.
3. Letter of the Principal, St.Mary's D.Ed College, Lingareddy Pally, Siddipet, Medak District.
4. Inspection report Rc.No.254/ADFO & SFO/SDPT/2014, Dt.29-01-2015 of the Assistant District Fire Officer, Medak and Station Fire Officer, Siddipet.

\$ \$ \$ \$ \$

Vide reference 3rd cited, the Principal, St.Mary's D.Ed College has reported that he has constructed Educational Building without obtaining Provisional No Objection Certificate from this Department and requested to issue the No Objection Certificate for Occupancy to the Existing Educational building of St.Mary's D.Ed College, Sy.No.381,382, Lingareddy Pally, Siddipet, Medak District.

2 Vide reference 4th cited, the Assistant District Fire Officer, Medak District and the Station Fire Officer, Siddipet inspected the building on 29-01-2015 and recommended for the issue of No Objection Certificate for Occupancy to the above Educational Building.

3. Particulars of the Educational Building:

i) Height of the Building: **Block-A -- 03.30Mtrs and Block B --06.30 Mtrs**

ii) Open spaces:

Direction	Required as per NBC-2005	Provided	Deficit/Remarks
North	N.A	N.A	N.A
East	N.A	N.A	N.A
South	N.A	N.A	N.A
West	N.A	N.A	N.A

iii). Floor wise particulars:

Sl. No	Floor	Floor Area in Sq. Meters		Occupancy	No. of students & Staff members in the floor
		Block-A	Block-B		
1	Ground floor	429.06 Sq. Mtrs	536.80 Sq. Mtrs	Educational	100
2	First floor	--	536.80 Sq. Mtrs	Educational	50
		429.06 Mtrs	1073.60 Mtrs	--	--
	Total:	1502.66 Mtrs		--	150

The Management has remitted Rs.18,650=00 (Rupees Eighteen thousand six hundred and fifty only) vide Challan No.0000033396, Dt.21-01-2015 at SBH., Siddipet Branch towards the fire precaution fee and penal amount.

(PTO)

iv) (a) Means of Escape :

Sl.No.	Details of Staircase	Provided	
		Nos	Width in Meters
1	Internal Staircases.	01 No.	1.00 M
2	External Staircases	--	
	Total	01 No.	1.00 Mtrs

(b) Details of Occupant Load per unit Exit Width in each floor:

Sl No	Floor	Built up Area in Sq Mtrs		No.of Occupants		Means of Escape as per NBC-2005		Provided	
		Block-A	Block-B	Block-A	Block-B	Block-A	Block-B	Block-A	Block-B
1	Ground	429.06 Sq. Mtrs	536.80 Sq. Mtrs	50	50	--	--	--	--
2	First floor	--	536.80 Sq. Mtrs	NA	50	NA	01.00	N.A	01.00

V) (1) Fire Safety Measures:

Sl. No	Fire safety Measures	Required as per Table 23 of NBC of India 2005	Provided	Deficiency
1	Fire Extinguishers	15 No.s	15 No.s	Nil
2	Hose Reel	N.A	N.A	N.A

(2) Floor wise fire fighting Installations provided by the management:

Sl.No	Floor	Extinguishers		Hose Reel	Automatic Sprinkler System	Terrace Tank	Fire Pumps
		Block-A	Block-B				
1	Ground	05 No.s	05 No.s	NA	NA	NA	NA
2	First Floor	--	05 No.s	NA	NA	NA	NA
	Total	05 No.s	10.No.s	-	-	-	-


4. The Existing Educational Building of St.Mary's D.Ed College, Sy.No.381,382, Lingareddy Pally, Siddipet, Medak District has provided with Fire Safety measures prescribed in Part 4, NBC - 05.

5. Therefore, the No Objection for Occupancy is issued to the Existing Educational building of St.Mary's D.Ed College, Sy.No.381,382, Lingareddy Pally, Siddipet, Medak District., subject to the following conditions.


i.	All the fire protection arrangements shall be maintained in good condition as seen during inspection.
ii.	All the escape / exit routes shall not be kept locked / blocked or encroached.
iii.	All the occupants must know the correct method of operation of the fire fighting system installed.
iv.	Any loss of life or property due non-functioning of fire safety measures and other installations shall be the responsibility of the management.
v.	All Students / Staff members of the institutions shall be trained to operate the fire safety equipments during emergency.
vi.	Addition / alteration, if any in the building may be obtained with prior permission from this Department.
vii.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 Months.

6. This Occupancy Clearance is valid for a period of One year only ie., 29-01-2016. The Management is requested to submit application for renewal of No Objection Certificate for Occupancy before one month of expiry of the Certificate.

Yours faithfully,


30/1/15
District Fire Officer,
Medak District.

Copy to the Asst. District Fire Officer, Medak District.
Copy to the Station Fire Officer, Siddipet.


30.1.15